



**NOTES**

DO NOT SCALE FROM THIS DRAWING.  
ALL DIMENSIONS TO BE CHECKED ON SITE.  
COPYRIGHT PROTECTED.

ORIGINAL

Symbol	Provision	Contractor Maintenance FM Compliance	Store Testing - Opening & Closing Book
	Water Fire Extinguisher	Annual	Visual by Store - Monthly
	Carbon Dioxide Fire Extinguisher	Annual	Visual by Store - Monthly
	Dry Powder Fire Extinguisher	Annual	Visual by Store - Monthly
	Foam Fire Extinguisher	Annual	Visual by Store - Monthly
	Fire Panel	6 Monthly (Eire 4 monthly)	
	Fire Shutter	Annual or 6 Monthly	
	Fire Curtain	Annual or 6 Monthly	
	Emergency Lighting Terminal		Full Walk Test - Monthly
	Hose Reels	Annual or 6 Monthly	
	Dry Riser		
	Illuminated Fixed Signage		Visual by store Daily
	Mid-Floor Directional Signage		Visual by store Daily
	Fire Alarm Call Point	With Fire Panel Maintenance	Weekly by Store - MCP Not Recorded
	Yellow Break Glass	PPM	
	Green Break Glass	PPM	
	Smoke Detectors	6 Monthly (Eire 4 monthly)	
	Heat Detectors	6 Monthly (Eire 4 monthly)	
	Sounder	With Fire Panel Maintenance	
	Beacon	With Fire Panel Maintenance	
	Sounder with Beacon	With Fire Panel Maintenance	
	Disabled Refuge		Monthly by Store
	Disabled Refuge Call Point		Monthly by Store
	Evacuation Chair		3 Monthly by Store
	Red Route - Escape route to be kept clear		Visual by Store

REV	DATE	DESCRIPTION	DRAWN	CHECKED
03	L 03/19	UPDATED AS PER RECEIVED PLANS	IMD	GR
02	K 04/16	UPDATED AS PER RECEIVED PLANS	IMD	BELH
01	J 05/15	UPDATED AS PER RECEIVED PLANS	IMD	BELH

CLIENT  
  
 FireHealthandSafety@marks-and-spencer.com

PROJECT  
 Fire Risk Site Plan

DRAWING  
 M&S Warwick  
 First Floor Plan

CONSULTANT  
  
 CALLIDUS HEALTH & SAFETY  
 3 LANDMARK COURT  
 REVIE ROAD  
 LEEDS, LS11 8JT  
 TEL: 0113 385 2740

DRAWING No	SCALE	DATE	CHECKED	REV
0073-1	NTS	21/03/2019	GR	L

NB: NOT A DIGITAL SURVEY ALL DIMENSIONS TO BE SITE CHECKED