

# KEY

PICTOGRAMS/SIGNAGE  
to Council Directive 92/58/EEC  
note: Illustrations below indicative only

1. FIRE EXIT  
2. FIRE EXIT  
3. FIRE EXIT  
4. FIRE EXIT  
5. FIRE EXIT

RECOMMENDED INSTALLATION HEIGHTS  
Above doors - 2.0m-2.5m from floor level to base of sign  
Directional wall fixed signs - 1.7m-2.0m from floor level to base of sign

ONE HOUR FIRE SEPARATION  
HALF HOUR FIRE SEPARATION

Manual/Break Glass Call Point

HEATHCOTE LANE



NO CHANGE TO FIRE STRATEGY TO  
WAREHOUSE(S) AS PART OF BUILDING  
REGULATIONS APPLICATION - ALL EXISTING  
EQUIPMENT/SIGNAGE RETAINED.  
HOWEVER - RECOMMENDATION TO  
CLIENT TO CHANGE EXISTING BREAK  
GLASS LOCKS TO PUSH BAR OR  
PUSH PAD TO IMPROVE EXISTING FIRE SAFETY

FIRE ALARM SYSTEM TO  
SERVICES ENGINEER'S  
SPECIFICATION.  
FIRE EXTINGUISHER TYPES  
AND POSITIONS  
TO FIRE OFFICER'S  
RECOMMENDATIONS

**MPC**

PARTNERSHIP 8 Euston Place Royal Leamington Spa  
CV32 4LN Tel: (01928) 833355 Fax: 886888

PROJECT **WANZL DISTRIBUTION CENTRE  
PROPOSED EXTENSION**

SITE LOCATION  
EUROPA HOUSE, HEATHCOTE LANE  
WARWICK, CV34 6SP

DRG TITLE  
**PROPOSED GROUND FLOOR  
FIRE STRATEGY PLAN**

© copyright 2005 Scales 1:200	Drawn by JM/HKM Date 07/11/05	Checked by JM Date 11/11/05
DRG NO.		574/BR/106